

Capital Facilities Planning

Addendum

To: Prospective Bidders

From: Muneeza Ismail
Project Manager, Capital Facilities Planning

Re: Addendum No. 3 – Clarification Regarding Detail 26/Drawing 104 Rev “0”
SU-021919 Natural Gas Line to Physical Education Building

DATE: MARCH 21ST, 2019

Detail No. 26 of Drawing No. SU-104 matches the construction of the existing retaining wall. The scope of this project includes restoration of the areas affected by this project to match the existing construction. The location of the existing retaining wall is shown on Drawing No. SU-101 Rev’0”.

The amount of retaining wall to be removed for pipe installation is to be determined by the contractor based on the width of the excavation/trenching at this location.