

Purchase College Solicitation # SU-031819  
Campus Roadways Rehabilitation Project

**Addendum #03**

April 25, 2019

Questions and Answers

1. How should contractors bid on the granite curbing to keep things apples to apples?
  - a. **Granite curbing shall be bid on a unit price to include labor and material.**
  
2. After removing the top course of asphalt, how long can the sub base be exposed before installing the new top course of asphalt?
  - a. **Removal of existing asphalt top course shall be performed in one (1) day and new asphalt for that area must be installed the following day. We do not want the sub base to be exposed for more than one (1) day.**