

Summer 2018 Water Testing

Date	Building	General Loc	Specific Loc	Cu FD ug/L	Pb FD ug/L	Cu Flush ug/L	Pb Flush ug/L	Coliform
7/3/2018	Dorm	E/F	Hydration	237	<LOQ		88	<LOQ
7/3/2018	Phase II		Hydration	166	1.6		19.5	<LOQ
7/3/2018	Outback		Hydration	165	<LOQ		33.7	<LOQ
7/3/2018	AV	AV10	Hydration	134	<LOQ		35.6	<LOQ
7/3/2018	Phase I	West	West Hydration	167	<LOQ		47.9	<LOQ
7/3/2018	Phase I	East	East Hydration	233	<LOQ		18.8	<LOQ
7/3/2018	Dorm	C/D	Hydration	171	<LOQ		75.7	<LOQ
7/3/2018	Dorm	A/B	Hydration	160	<LOQ		69.8	<LOQ
7/9/2018	Ft. Awe		Hydration	362	<LOQ		69.8	<LOQ
7/10/2018	Phase II	K-3-2	Kitchen	270	1		14.2	<LOQ
7/10/2018	Phase II	K-3-4	Kitchen	608	<LOQ		9.8	<LOQ
7/10/2018	Butler	Child Ctr	Kitchen	178	<LOQ		117	<LOQ
7/10/2018	Phase II	K-3-5	Kitchen	169	4.5		7.3	<LOQ
7/10/2018	Phase II	P-3-5	Bathroom	38	<LOQ		19.8	<LOQ
7/10/2018	Butler	Child Ctr	Water Fountain	124	<LOQ		87	<LOQ
7/11/2018	Stu Serv	1 Fl	Water Fountain	98.5	<LOQ		41.8	<LOQ
7/11/2018	AV	AV3-2	Kitchen	133	1.9		14.8	<LOQ
7/11/2018	Soc Sci	Basement	Water Fountain	123	2.7		26.9	<LOQ
7/11/2018	Library	Basement	S Water Fountain	458	<LOQ		39.1	<LOQ
7/27/2018	Phase II	M-3-5	Kitchen	78.2	1.8		55.7	<LOQ
7/27/2018	Phase II	M-3-5	Bathroom	81.9	<LOQ		66.4	<LOQ
8/8/2018	Dorm	B213	Left Sink	558	6.6	11.5		<LOQ
8/8/2018	Dorm	B Lounge	ADA restroom	2630	12		33.7	<LOQ
8/8/2018	Dorm	B113	Sink	3820	25.4		25.2	<LOQ
8/8/2018	Dorm	B09	Sink	918	21.8		19.8	<LOQ
8/8/2018	Dorm	B213	Middle Sink	95.2	<LOQ		10.7	<LOQ
8/8/2018	Dorm	B213	Right Sink	415	1.2		7.4	<LOQ
8/8/2018	Dorm	A223	Right Sink	172	1.8		33.8	<LOQ
8/8/2018	Dorm	A233	Middle Sink	44.3	<LOQ		26.2	<LOQ
8/8/2018	Dorm	A233	Left Sink	78.1	1.4		26.8	<LOQ
8/8/2018	Dorm	A131	Sink	614	6.2		63.1	<LOQ
8/8/2018	Dorm	B310	Right Sink	16.5	<LOQ		11.8	<LOQ

8/8/2018	Dorm	B310	Left Sink	214	<LOQ	14.9	<LOQ	
8/8/2018	Dorm	B310	Middle Sink	42.2	<LOQ	12.8	<LOQ	
8/8/2018	Dorm	A337	Middle Sink	264	1.6	22	<LOQ	
8/8/2018	Dorm	A337	Right Sink	36.2	<LOQ	22.6	<LOQ	
8/8/2018	Dorm	A337	Left Sink	171	<LOQ	24.1	<LOQ	
8/31/2018	Phase I	East	East Hydration					Absent
8/31/2018	Ft. Awe		Hydration					Absent
8/31/2018	Dorm	C/D	Hydration					Absent
8/31/2018	Phase I	West	West Hydration					Absent
8/31/2018	Phase II		Hydration					Absent
8/31/2018	AV	AV10	Hydration					Absent
8/31/2018	Dorm	A/B	Hydration					Absent
8/31/2018	Dorm	E/F	Hydration					Absent
8/31/2018	Outback		Hydration					Absent

EPA Action Level 15 ug/L pb and 1300 ug/L cu