

2018-2019 Water Testing								
Date	Building	General Loc	Specific Loc	Cu FD ug/L	Cu Flush ug/L	Pb FD ug/L	Pb Flush ug/L	Coliform
7/3/2018	Dorm	E/F	Hydration	237	88	<LOQ	<LOQ	
7/3/2018	Phase II		Hydration	166	19.5	1.6	<LOQ	
7/3/2018	Outback		Hydration	165	33.7	<LOQ	<LOQ	
7/3/2018	AV	AV10	Hydration	134	35.6	<LOQ	<LOQ	
7/3/2018	Phase I	West	West Hydration	167	47.9	<LOQ	<LOQ	
7/3/2018	Phase I	East	East Hydration	233	18.8	<LOQ	<LOQ	
7/3/2018	Dorm	C/D	Hydration	171	75.7	<LOQ	<LOQ	
7/3/2018	Dorm	A/B	Hydration	160	69.8	<LOQ	<LOQ	
7/9/2018	Ft. Awe		Hydration	362	69.8	<LOQ	<LOQ	
7/10/2018	Phase II	K-3-2	Kitchen	270	14.2	1	<LOQ	
7/10/2018	Phase II	K-3-4	Kitchen	608	9.8	<LOQ	<LOQ	
7/10/2018	Butler	Child Ctr	Kitchen	178	117	<LOQ	<LOQ	
7/10/2018	Phase II	K-3-5	Kitchen	169	7.3	4.5	<LOQ	
7/10/2018	Phase II	P-3-5	Bathroom	38	19.8	<LOQ	<LOQ	
7/10/2018	Butler	Child Ctr	Water Fountain	124	87	<LOQ	<LOQ	
7/11/2018	Stu Serv	1 Fl	Water Fountain	98.5	41.8	<LOQ	<LOQ	
7/11/2018	AV	AV3-2	Kitchen	133	14.8	1.9	<LOQ	
7/11/2018	Soc Sci	Basement	Water Fountain	123	26.9	2.7	<LOQ	
7/11/2018	Library	Basement	S Water Fountain	458	39.1	<LOQ	<LOQ	
7/27/2018	Phase II	M-3-5	Kitchen	78.2	55.7	1.8	<LOQ	
7/27/2018	Phase II	M-3-5	Bathroom	81.9	66.4	<LOQ	<LOQ	
8/8/2018	Dorm	B213	Left Sink	558	11.5	6.6	<LOQ	
8/8/2018	Dorm	B Lounge	ADA restroom	2630	33.7	12	<LOQ	
8/8/2018	Dorm	B113	Sink	3820	25.2	25.4	<LOQ	
8/8/2018	Dorm	B09	Sink	918	19.8	21.8	<LOQ	
8/8/2018	Dorm	B213	Middle Sink	95.2	10.7	<LOQ	<LOQ	
8/8/2018	Dorm	B213	Right Sink	415	7.4	1.2	<LOQ	
8/8/2018	Dorm	A223	Right Sink	172	33.8	1.8	<LOQ	
8/8/2018	Dorm	A233	Middle Sink	44.3	26.2	<LOQ	<LOQ	
8/8/2018	Dorm	A233	Left Sink	78.1	26.8	1.4	<LOQ	
8/8/2018	Dorm	A131	Sink	614	63.1	6.2	<LOQ	
8/8/2018	Dorm	B310	Right Sink	16.5	11.8	<LOQ	<LOQ	

2018-2019 Water Testing								
Date	Building	General Loc	Specific Loc	Cu FD ug/L	Cu Flush ug/L	Pb FD ug/L	Pb Flush ug/L	Coliform
8/8/2018	Dorm	B310	Left Sink	214	14.9	<LOQ	<LOQ	
8/8/2018	Dorm	B310	Middle Sink	42.2	12.8	<LOQ	<LOQ	
8/8/2018	Dorm	A337	Middle Sink	264	22	1.6	<LOQ	
8/8/2018	Dorm	A337	Right Sink	36.2	22.6	<LOQ	<LOQ	
8/8/2018	Dorm	A337	Left Sink	171	24.1	<LOQ	<LOQ	
8/31/2018	Phase I	East	East Hydration					Absent
8/31/2018	Ft. Awe		Hydration					Absent
8/31/2018	Dorm	C/D	Hydration					Absent
8/31/2018	Olde	West	West Hydration					Absent
8/31/2018	Commons		Hydration					Absent
8/31/2018	AV	AV10	Hydration					Absent
8/31/2018	Dorm	A/B	Hydration					Absent
8/31/2018	Dorm	E/F	Hydration					Absent
8/31/2018	Outback		Hydration					Absent
1/2/2019	Ft. Awe	263	Sink	224	193	<LOQ	<LOQ	
1/2/2019	Ft. Awe	258	Sink	196	152	<LOQ	<LOQ	
1/2/2019	Outback	327	Sink	230	189	<LOQ	<LOQ	
1/2/2019	Dorm	B250	Sink A	16.1	3.5	2	<LOQ	
1/2/2019	Ft. Awe	201	Sink D	156	154	9.3	<LOQ	
1/2/2019	Ft. Awe	202	Sink B	640	27.1	<LOQ	<LOQ	
1/2/2019	Dorm	A107	Sink B	5.1	6.5	<LOQ	<LOQ	
1/3/2019	Commons	P-4-3	Bathroom Sink A	38.8	12.3	<LOQ	<LOQ	
1/3/2019	Olde	J-3-4	Kitchen	140	90	<LOQ	<LOQ	
1/3/2019	AV	AV-6-4	Bathroom	148	21.3	<LOQ	<LOQ	
1/3/2019	AV	AV-4-1	Bathroom	68.7	23	<LOQ	<LOQ	
1/3/2019	AV	AV-11-1	Kitchen	173	12.5	<LOQ	<LOQ	
1/3/2019	Music	1016	Kitchen	331	93.2	5.9	<LOQ	
1/3/2019	Olde	G-1-3	Bathroom Sink A	172	5.3	5.1	<LOQ	
1/3/2019	Olde	G-7-4	Bathroom Sink A	132	13.9	2	<LOQ	
1/3/2019	Commons	M-4-6	Bathroom Sink B	13.4	7.5	<LOQ	<LOQ	
1/3/2019	Commons	K-5-4	Bathroom Sink B	137	10.1	1.1	<LOQ	
1/3/2019	Olde	H-1-1	Kitchen	118	6.3	1.9	<LOQ	

2018-2019 Water Testing								
Date	Building	General Loc	Specific Loc	Cu FD ug/L	Cu Flush ug/L	Pb FD ug/L	Pb Flush ug/L	Coliform
1/9/2019	Butler	Stood	E Male Sink A	94.3	96.4	7	<LOQ	
1/9/2019	Butler	Stood	E Female Sink A	233	108	5.3	<LOQ	
1/9/2019	Butler	Stood	E Female Sink B	230	109	9	<LOQ	
1/9/2019	Butler	Stood	Water Fountain	139	116	1.2	<LOQ	
1/9/2019	Butler	Stood	E Male Sink B	113	107	10	3.6	
1/9/2019	Butler	Stood	W Unisex Sink A	217	90	28.1	1.9	
1/10/2019	CCN	3005	Bathroom	149	63.2	16.6	<LOQ	
1/10/2019	CCN	3rd Fl	E Bathroom	166	17	2.1	<LOQ	
3/25/2019	PAC	A13	Bathroom Sink C	196	58.4	4.6	<LOQ	
3/25/2019	PAC	A13	Bathroom Sink A	69	59.1	<LOQ	<LOQ	
3/25/2019	Olde	H-6-1	Bathroom Sink B	26.6	23.2	<LOQ	<LOQ	
3/25/2019	PAC	A4	Sink	235	75.4	3.4	<LOQ	
3/25/2019	Dance	1014	Sink B	167	96.4	<LOQ	<LOQ	
3/25/2019	Music	3 Fl Men	Bathroom Sink B	160	13.8	2.1	<LOQ	
3/25/2019	Gym	1 Fl Men	Bathroom Sink D	155	84.9	4.2	<LOQ	
3/25/2019	Olde	H-1-3	Bathroom Sink B	40.7	4.5	<LOQ	<LOQ	
3/25/2019	PAC	A14	Bathroom Sink C	87	67.8	<LOQ	<LOQ	
3/26/2019	Dorm	A29	Sink	228	<LOQ	<LOQ	<LOQ	
3/26/2019	AV	AV-10-3	Kitchen	339	17.1	<LOQ	<LOQ	
3/26/2019	Dorm	A29	Bathroom Sink	15.5	2.4	<LOQ	<LOQ	
3/26/2019	AV	AV-9-1	Kitchen	60.5	28.2	<LOQ	<LOQ	
3/26/2019	AV	AV-9-5	Kitchen	148	19.7	<LOQ	<LOQ	
3/26/2019	AV	AV-7-3	Kitchen	166	11.9	<LOQ	<LOQ	
3/26/2019	Dorm	A107	Bathroom Sink	2.7	4	<LOQ	<LOQ	
3/26/2019	Dorm	A116	Bathroom Sink A	1.6	1.4	<LOQ	<LOQ	
3/26/2019	Dorm	B302	Bathroom Sink C	34.9	10.8	<LOQ	<LOQ	
3/26/2019	Dorm	A119	Bathroom Sink	2.7	2.6	<LOQ	<LOQ	
3/27/2019	Commons	M-1-3	Kitchen	10.6	4.3	<LOQ	<LOQ	
3/27/2019	Commons	M-3-6	Kitchen	47.1	18.7	<LOQ	<LOQ	
3/27/2019	Commons	M-2-1	Bathroom Sink	15.8	13.3	<LOQ	<LOQ	
3/27/2019	Commons	K-4-3	Bathroom Sink B	57.3	22.8	<LOQ	<LOQ	
3/28/2019	Ft. Awe	464	Kitchen	318	28.4	<LOQ	<LOQ	

2018-2019 Water Testing								
Date	Building	General Loc	Specific Loc	Cu FD ug/L	Cu Flush ug/L	Pb FD ug/L	Pb Flush ug/L	Coliform
3/28/2019	Ft. Awe	357	Bathroom Sink	88.3	8.4	<LOQ	<LOQ	
3/28/2019	Ft. Awe	355	Bathroom Sink	87.7	8.1	<LOQ	<LOQ	
3/28/2019	Ft. Awe	340	Bathroom Sink	140	11.6	1	<LOQ	
3/28/2019	Ft. Awe	314	Bathroom Sink	33.1	12.2	<LOQ	<LOQ	
3/28/2019	Ft. Awe	268	Bathroom Sink	102	12.8	<LOQ	<LOQ	
3/28/2019	Outback	Laundry Rm	Sink	71.1	6.4	<LOQ	<LOQ	
3/28/2019	Outback	222	Bathroom Sink	172	12.7	4.3	<LOQ	
3/28/2019	Commons	P-1-3	Kitchen	94.9	15.8	<LOQ	<LOQ	
3/28/2019	Commons	P-3-6	Kitchen	51.1	9.5	<LOQ	<LOQ	
3/28/2019	Commons	S-1-3	Kitchen	59.9	10.1	<LOQ	<LOQ	
3/28/2019	Commons	S-3-2	Kitchen	50.8	14.3	<LOQ	<LOQ	
4/9/2019	Dorm	Dining	Sink 3 by Rational Oven	155	10.1	1.7	<LOQ	

EPA Action Levels:

Lead 15 ug/L

Copper 1300 ug/L