

Purchase College Solicitation # SU-031819
Campus Roadways Rehabilitation Project

Addendum #04

April 26, 2019

1. Provide specifications for asphalt sealant (Matl Type, Application Rate)
See attached Addendum 4 Attachment A titled "ITEM 410.20400001 – SEAL COATING ASPHALT SURFACES"
2. Provide specifications for Pavement Markings (Material Type , Application Rate)
See attached Addendum 4 Attachment B titled "Pavement Marking Material Guidelines" page 4 and Addendum 4 Attachment C titled "Epoxy Paint Line Specification".
3. Project Scope of work makes comment to full depth pavement repair, however, there are no quantities or limits of repair provided.
 - a. Refer to Sect 1.(b).vii and xiii
 - b. Suggest unit pricing:
 - i. <250 sf
 - ii. >250 sf**See Addendum 2**
4. Need detail and specifications addressing the need to repair and replace existing Cobble stone curbing. ADD: Unit Pricing
See Addendum 3
5. In order to achieve proper pitch in grade along shoulders and centerline crown, an added layer of asphalt may be needed. This is generally performed through a line item "True and Leveling", ADD: Unit price= Per Ton.
See Addendum 2
6. Speed Bumps: Existing Speed Bumps are hand laid asphalt pavement. You asked for the Speed bumps to be replaced as shown in Detail SD-2, Plan RE-1.
 - a. Please clarify if the new should be asphalt as exists OR Preformed rubber as shown in detail.**Speed bumps shall be manufactured by Post Guard model "Easy Rider Speed Bump" 8'-0" in length or equal. Easy Rider Speed Bump (or equal) shall include 2 end caps for each speed bump and associated mounting hardware. Easy Rider Speed Bump's (or equal) shall be installed per the manufacturer's specifications.**
7. Comment and discussion took place that the plans and specs were not created by a licensed architect or engineer.
 - a. If the instructions were provided by another skilled contractor in the asphalt profession, is this contractor able to bid on this project?**Project was publically posted and open to all qualified bidders.**

Purchase College Solicitation # SU-031819
Campus Roadways Rehabilitation Project

Addendum #04

April 26, 2019

8. Please provide engineers estimate for this project (including Alternates)
Plans and specifications were developed by SUNY Purchase Project Manager based on information obtained from the NYS DOT website.