



# Purchase College

STATE UNIVERSITY OF NEW YORK

735 Anderson Hill Road  
Purchase, NY 10577-1402  
www.purchase.edu

Procurement Department  
IFB - Oil Tank Replacement  
Project SU-060122  
Addendum #1 \* June 21, 2022

To: Prospective Bidders

No. of Pages: 2 pages

SUNY Purchase hereby issues this Addendum, dated 6/21/2022, for the above referenced IFB, in order to provide the following clarifications:

**Item 1:**

SUNY Purchase received questions at the pre-bid meeting and via email. Answers with additional clarification is provided on the following page.

---

---

Please be sure to sign THIS ADDENDUM (as acknowledgment that your firm received it) and submit it with your bid package.

Respectfully,

Sheli Taylor  
Associate Director of Contract & Procurement Services

Acknowledgement of ADDENDUM #1

\_\_\_\_\_  
Signature                      Date

\_\_\_\_\_  
Typed printed name and title

\_\_\_\_\_  
Company name

## Capital Facilities Planning

---

To: Prospective Bidders

From: Muneeza Ismail  
Project Manager, Capital Facilities Planning

Re: Addendum No. 1 Answers to bidders questions  
SU-060122 – Oil Tank Replacement

DATE: JUNE 21<sup>s</sup>, 2022

---

This memorandum is hereby issued and published on the Purchase College Website on June 21, 2022. Except as modified herein, the project specifications remain unchanged. This Addendum forms a part of the Bidding Documents and is hereby incorporated into the Contract Documents.

---

**Question #1 - Is this a union job?**

Answer #1 – No, but NY State prevailing wages apply for all workers.

**Question #2 - Are subcontractors allowed on this project?**

Answer #2 – No, the work must be self-performed.

**Question #3 - What is the expected depth of the trenching?**

Answer #3 – About 24” to 36”

**Question #4 – Section 231323-2 of the specifications, Part 2, products, section 2.1, states the tank should be UL-142. However, part D states the tank should be UL 2085. Please clarify.**

Answer #4 – The tank shall be manufactured in accordance with UL-142 not UL-2085.

Coatings: The tank and all accessories included with the tank shall be:

- a. Primer: Corrosion resistant epoxy or urethane.
- b. Top Coat: Epoxy or urethane.
- c. Color Code the fill Port: Green