

2023 Water Testing

Date	Building	General Location	Source Description	Cu ug/L First Draw 1300 ug/L	Re-Sample Cu ug/L Flush 1300 ug/L	Pb ug/L First Draw 15 ug/L	Pb ug/L Flush 15 ug/L	Comments
01/10/2023	Admissions	1st Floor	Kitchenette, Sink	41.0		<LOQ	<LOQ	
01/10/2023	CFP	1st Floor	Kitchenette, Sink	238.0		<LOQ	<LOQ	
01/10/2023	Children's Center	1st Floor	Kitchenette, Sink	90.4		<LOQ	<LOQ	
01/10/2023	Humanities	1st Floor	Hydration Station	50.3		<LOQ	<LOQ	
01/10/2023	Humanities	2nd Floor	Men's Room, Sink on right.	542.0		<LOQ	<LOQ	
01/10/2023	Humanities	Lower Level	Water Fountain, Left, near 0043	1640.0		<LOQ	<LOQ	
02/07/2023	Humanities	Lower Level	Water Fountain, Left, near 0043. Re-sampled.	2060.0	266.0	<LOQ	<LOQ	
04/18/2023	Humanities	Lower Level	Water Fountain, Left, Near 0043. Re-sampled.	2530.0		N/A	N/A	
04/18/2023	Humanities	Lower Level	Water Fountain, Left, Near 0043. Re-sampled.	2450.0		N/A	N/A	
01/10/2023	Humanities	Lower Level	Men's Room, Sink on left.	450.0		1.2	<LOQ	
01/10/2023	RTA	2nd Floor	Kitchenette, Sink	1.8		<LOQ	<LOQ	
01/10/2023	Stood		Water Fountain to right of room 1007	618.0		<LOQ	<LOQ	
01/12/2023	Campus Center South	1st Floor	Men's Room Sink, Left	77.8		<LOQ	<LOQ	
02/06/2023	Campus Center South	3rd Floor	Water Fountain at end of hallway. Re-sampled.	483.0	109.0	11.9	1.7	Fountain is off.
04/18/2023	Campus Center South	3rd Floor	Water Fountain at end of hallway. Re-sampled.	N/A		14.1	N/A	Fountain is off.
04/18/2023	Campus Center South	3rd Floor	Water Fountain at end of hallway. Re-sampled.	N/A		12.0	N/A	Fountain is off.
01/12/2023	Campus Center South	Lower Level	SHS, Kitchenette, Sink	283.0		<LOQ	<LOQ	
01/12/2023	Student Services	1st Floor	Men's Room, Sink on left	137.0		<LOQ	<LOQ	
01/12/2023	Student Services	1st Floor	Water Fountain / Hydration Station	113.0		<LOQ	<LOQ	
01/12/2023	Student Services	2nd Floor	Water Fountain, Left	147.0		<LOQ	<LOQ	
01/12/2023	Student Services	3rd Floor	Water Fountain, Left	113.0		<LOQ	<LOQ	
01/12/2023	Visual Arts	1st Floor	Water Fountain by room 1008	86.0		<LOQ	<LOQ	
01/12/2023	Visual Arts	1st Floor	Men's Room, Sink on left	34.1		4.9	2.4	
01/12/2023	Visual Arts	2nd Floor	Men's Room 2007, Sink, Right	70.9		14.7	1.6	
02/06/2023	Visual Arts	2nd Floor	Men's Room 2007, Sink, Right. Re-sampled.	87.0	25.1	8.6	<LOQ	
01/13/2023	Campus Center North	2nd floor by elevator	Hydration Station by elevator	202.0		4.0	2.1	
01/13/2023	Campus Center North	1st floor, near 1006	Water Fountain by room 1006	187.0		3.0	<LOQ	
01/13/2023	CMFT	1st Floor	Water Fountain, near 1037 / 1038	305.0		<LOQ	<LOQ	
01/13/2023	CMFT	3rd Floor	Water Fountain, near 3040 / 3041	1800.0	976.0	<LOQ	<LOQ	
02/06/2023	CMFT	3rd Floor	Water Fountain, near 3040 / 3041. Re-sampled.	906.0	261.0	<LOQ	<LOQ	
04/18/2023	CMFT	3rd Floor	Water Fountain, near 3040 / 3041. Re-sampled.	872.0		N/A	N/A	

2023 Water Testing

Date	Building	General Location	Source Description	Cu ug/L First Draw 1300 ug/L	Re-Sample Cu ug/L Flush 1300 ug/L	Pb ug/L First Draw 15 ug/L	Pb ug/L Flush 15 ug/L	Comments
04/18/2023	CMFT	3rd Floor	Water Fountain, near 3040 / 3041. Re-sampled.	758.0		N/A	N/A	
01/13/2023	CMFT	3rd Floor	Kitchenette, Sink, MFA 3043	498.0		<LOQ	<LOQ	
01/13/2023	Library	1st Floor	Water Fountain, near Men's 1012	617.0		6.2	5.1	
01/13/2023	Library	Lower Level	Learning Center, Hydration St.	126.0		<LOQ	<LOQ	
01/13/2023	Social Sciences	1st Floor	Water Fountain by room 1036	327.0		<LOQ	<LOQ	
01/13/2023	Social Sciences	2nd Floor	Men's Room Sink, center	71.2		2.2	<LOQ	
01/13/2023	Social Sciences	Lower Level	Men's Room, Sink, center	36.4		<LOQ	<LOQ	
01/17/2023	Music	Lower Level	Men's Room, Sink on Left	15.8		<LOQ	<LOQ	
01/17/2023	Music	2nd Floor	Water Fountain on Right by room 2035	127.0		1.5	<LOQ	
01/17/2023	Music	1st Floor	Water Fountain / Hydration Station by room 1058	108.0		<LOQ	<LOQ	
01/17/2023	PAC	1st Floor	Men's Room, Sink, Center out of five	204.0		1.7	<LOQ	
01/17/2023	PAC	1st Floor	Hydration Station, Lobby, next to Men's Room	202.0		<LOQ	<LOQ	
01/17/2023	PAC	Lower Level	Ladies' Room, Sink, Left, room L324	217.0		5.0	1.0	
01/17/2023	PAC	Lower Level	Men's Room, Sink, Left, room L121	295.0		4.7	3.5	
01/17/2023	Physical Education	2nd Floor	Hydration Station, near 2013	117.0		<LOQ	<LOQ	
01/17/2023	Physical Education	Lower Level	Weight Room, Water Fountain / Hydration Station	37.6		<LOQ	<LOQ	
01/17/2023	Physical Education	2nd Floor	Men's Room, Sink, Left, near 2013	187.0		1.4	<LOQ	
01/18/2023	Dance	Lower Level	Water Fountain across from room 0013	170.0		<LOQ	<LOQ	
01/18/2023	Dance	Lower Level	Restroom, Sink, room 0012	101.0		<LOQ	<LOQ	
01/18/2023	Dance	1st Floor	Water Fountain in center hallway	620.0		1.6	<LOQ	
01/18/2023	FMG	Main Building	Office Kitchenette, Sink	90.1		1.3	<LOQ	
01/18/2023	FMG	Heating Plant	Restroom, Sink, Right	45.1		<LOQ	<LOQ	
01/18/2023	Museum	1st Floor	Kitchenette, Sink	124.0		1.0	<LOQ	
01/18/2023	Museum	2nd Floor	Kitchenette, Sink	160.0		1.1	<LOQ	
01/18/2023	Natural Sciences	1st Floor	Hydration Station in hallway / lobby to right	129.0		<LOQ	<LOQ	
01/18/2023	Natural Sciences	2nd Floor	Water Dispenser, at 2062	456.0		5.4	3.9	
01/18/2023	Natural Sciences	3rd Floor	Men's Room across from room 3040, Sink on Left	56.5		1.1	<LOQ	
03/20/2023	Alumni Village	V1-4	Apartment Kitchen Sink - Occupied	202		<LOQ	<LOQ	
03/20/2023	Alumni Village	V2-6	Apartment Kitchen Sink - Occupied	197.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V3-8	Apartment Kitchen Sink - Vacant	141.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V4-3	Apartment Kitchen Sink - Vacant	194.0		<LOQ	<LOQ	

2023 Water Testing

Date	Building	General Location	Source Description	Cu ug/L First Draw 1300 ug/L	Re-Sample Cu ug/L Flush 1300 ug/L	Pb ug/L First Draw 15 ug/L	Pb ug/L Flush 15 ug/L	Comments
03/20/2023	Alumni Village	V5-5	Apartment Kitchen Sink - Occupied	191.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V6-7	Apartment Kitchen Sink - Occupied	215.0		1.0	<LOQ	
03/20/2023	Alumni Village	V7-1	Apartment Kitchen Sink - Occupied	147.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V8-2	Apartment Kitchen Sink - Vacant	183.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V9-7	Apartment Kitchen Sink - Occupied	155.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V10-2	Apartment Kitchen Sink - Vacant	289.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V11-6	Apartment Kitchen Sink - Vacant.	249.0		2.2	<LOQ	
03/20/2023	Alumni Village	V12-5	Apartment Kitchen Sink - Vacant	409.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	V13-2	Apartment Kitchen Sink - Occupied	239.0		<LOQ	<LOQ	
03/20/2023	Alumni Village	Community Center	Hydration Station, Fountain side	649.0		<LOQ	<LOQ	
03/21/2023	Wayback	1st Floor, Room 1003	Hydration Station, Fountain side	274.0		<LOQ	<LOQ	
03/21/2023	Wayback	2nd Floor, Room 2007	Hydration Station, Fountain side	203.0		<LOQ	<LOQ	
03/21/2023	Wayback	3rd Floor, Room 3007	Hydration Station, Fountain side	242.0		<LOQ	<LOQ	
03/21/2023	Wayback	4th Floor, Room 4007	Hydration Station, Fountain side	33.2		<LOQ	<LOQ	
03/21/2023	Wayback	1st Floor	Apartment, Kitchen Sink	278.0		<LOQ	<LOQ	

EPA Action Levels:

Lead 15 ug/L

Copper 1300 ug/L