

FREDERICK W. SEEBA, PE, MANAGING PARTNER
LAWRENCE SALVESEN, AIA, PARTNER
KEVIN J. WALSH, AIA, PARTNER
KENNETH G. SCHUPNER, AIA, PARTNER
JOSEPH B. RETTIG, AIA, PARTNER
GARY W. SCHIEDE, AIA, PARTNER
ROGER P. SMITH, AIA, FOUNDING PRINCIPAL

December 20, 2023

ADDENDUM NO. 1

Re: SUNY Purchase College
Multi-Purpose Synthetic Turf Facility
SU-092823 – General Construction
SU-092923 – Electrical Construction
State University of New York
BBS Project No. 23-158

This addendum contains changes to the requirements of the contract drawings and/or project manual. Such changes shall be incorporated into the contract documents and shall apply to the work with the same meaning and force as if they had been included in the original documents. Wherever this addendum modifies a portion of a paragraph of project manual or any portion of the drawing, the remainder of the paragraph or drawing affected shall remain in force.

The conditions of the basic project manual shall govern all work described in this addendum. Wherever the conditions of work and the quality or quantity of materials or workmanship are not fully described in this addendum, the conditions of work, etc. included in the basic project manual for similar items of work shall apply to the work described in this addendum.

The "Conditions of the Contract" apply to all work described in this addendum.

The following changes shall be and are hereby made:

GENERAL ITEMS

1. The General Construction Contract shall provide all trenching, excavation, backfill and restoration for the trenches required by the Electrical Construction Contract to install underground conduits related to that contract.
2. The Electrical Construction Contract is required to furnish and install the new 500 kVA transformer depicted on the sports lighting riser diagram (Dwg E2.02).

Addendum No. 1
December 20, 2023
Page 2

PROJECT MANUAL MODIFICATIONS

1. Specification Section 116843 – Electronic Scoreboards
The General Construction Contractor shall furnish and install the scoreboard. The Electrical Construction Contract shall provide all electrical related items and wiring / powering of the scoreboard. Note local Daktronics scoreboard sales representative contact is Long Island Gym, (631) 666-9513, Phil Coccarei, pcoccarei@ligym.com.
2. Specification 133423.11 – Prefabricated Press Box
The manufacturer shall ensure that the press box meets the current New York State Energy Code.

CONSTRUCTION DRAWING MODIFICATIONS

1. Drawing CS6.01 – Site Details, Detail 1 - Scoreboard Detail
The General Construction Contractor shall furnish and install the scoreboard. The Electrical Construction Contract shall provide all electrical related items and wiring / powering of the scoreboard.
2. Drawing E2.01 - Electrical Site Plan
The scale of this drawing is 1" = 20'-0".
3. Drawing E2.01 - Electrical Site Plan
The two (2) end speakers depicted on the press box are a Community R.5-HP-B loudspeaker.

End of Addendum No. 1

BBS Architects, Landscape Architects and Engineers, P.C.