## WATER TESTING LOG

DATE	SAMPLE #	LOCATION	CHLOR	PHOS	FLUOR
11.30.16	1	PAC Hydrant # 38	1.02	1.09	0.58
	2	Social Science basement Mens Room across from SS0020	1.06	1.08	0.5
	3	Library basement Mens Room sink	0.98	1.49	0.39
	4	Starbucks	1.1	1.2	0.49
	5	Fire Hydrant # 15 in Facilities Parking	0.62	1.01	0.7
	6	Phase 2 P-4 laundry room sink	0.98	1.16	0.41
	7	Phase 1 (Olde) Laundry room sink	1.05	1.16	0.67
	8	Museum basement Mens Room (Left of elevator)sink	0.98	1.27	0.49
	9	The Dorms Dining Hall kitchen sink.	0.86	1.22	0.49
	10	Alumni Village Building #10 entrance main in mechanical room. Boiler drain on main line.	0.81	1.17	0.54
	11	Physical Education water fountain at the far end of the pool	0.75	1.17	0.61
	12	Outback Laundry sink	0.91	1.19	0.52
		Acceptable Ranges:			
		Chlorine25 - 1.5			
		Phosohate .7 - 1.5			
		Fluoride .38			
ļ	1				