

Capital Facilities Planning

Addendum

To: Prospective Bidders

From: Muneeza Ismail
Project Manager, Capital Facilities Planning

Re: Addendum No. 3 to specifications SU-110514
Audio Visual Equipment and Installation at Humanities Building
Changes to Theater Equipment List requirements and Alternate #2

DATE: DECEMBER 11TH, 2014

- 1- Please see changes to main and surround loudspeakers, amplifiers and related equipment for the theater as indicated on the attached equipment list

- 2- Alternate #2 – Provide cost to add to the work of the Group III AV Systems contractor, termination at patchbays of all AV-signal field cables currently shown on the drawings as provided under the base AV infrastructure contract. Specifically excluded from this alternate is termination of "AV DATA" and "Campus LAN" field cables at network patchbays. (This exclusion applies only to "field" cables. Group III will still terminate AV-related network cables between network patchbays and rack-mounted AV equipment as shown on the drawings.) Per this alternate, Group III AV contractor will test (end-to-end), label, dress and terminate these infrastructure cables according to the standards in the Group III Specification and drawings. Include materials incidental to terminating these cables (e.g., heat-shrink, labels, tie wraps, et cetera)