

Capital Facilities Planning

ANSWERS TO QUESTIONS

To: All Bidders

DATE: MAY 19, 2014

FROM: Sayim Malik

SUBJECT: Acquisition and Installation of Dust Collector at Visual Arts Building, Purchase College SU-043014

This Answers to Questions is being issued for additional information and clarifications to the bid documents dated 04/30/14.

Question: The specification on page 0100-2 in the first paragraph mentions the dumpster hopper being required and also mentions the 55 gallon drum. Do we need to provide both?

Ans: 55 gallon drum is not required and can be deleted from the Bid.

Question : Does The (2) lathes and (1) band saw wires be removed and powered by a separate circuit?

Ans: Yes it will be on separate circuit. The campus understand that the dedicated power will be needed for the new 25 HP VFD that will control the fan motor on the Dust collector. The stolen power will be addressed by campus.

Question: There is light fixture on the exterior of the building which will be blocked by new duct system. Is it contractor responsibility to remove or relocate light fixture?

Ans: The light fixture will be relocated by campus.