

Capital Facilities Planning

Addendum

To: Prospective Bidders

DATE: May 5, 2014

FROM: Sayim Malik, Project Manager, Capital Facilities Planning

RE: Addendum No. 1

SU-043014 - Acquisition and Installation of a Dust Collector at Visual Arts Building Purchase College

Please be advised that the power requirements for the dust collector are 208/60/3 and not 460/60/3 as stated in the original General Requirements document page 0100-2.